

## CLASS 10000 HD SERIES 48 XC **RH ROTATION**





## **B = RUNNING POSITION OF BLADES**

- C = MAXIMUM DROOP POSITION OF BLADES
- D = MINIMUM OBSTACLE CLEARANCE AT INLET F = CENTERLINE OF FAN TO BASE OF BUSHING
- G = BUSHING OVERALL HEIGHT
- H = MINIMUM OBSTACLE CLEARANCE AT OUTLET
- I = NOMINAL MECHANICAL HUB DIAMETER
- L = MAXIMUM BUSHING TORQUE FT. LBS.
- # = WITH S.A.E. STANDARD SQUARE KEYWAY
- \*= WITH SHALLOW KEYWAY IN BUSHING <sup>O</sup>= MAX METRIC BORE WITH STANDARD KEYWAY
- BUSHING AND/OR AIR SEAL CAN BE INSTALLED ON INLET OR OUTLET SIDE OF FAN

						-	
		W					
		12000 FT/MINUTE BLADE TIP PERCENT BLADE LOADING					
			100%	75%			
	DIA	Α	В		С	D	н
	9'	14.9"	11.0"	10.5"	12.0"	4.0"	16"
	10'	14.2"	11.5"	10.8"	12.9"	4.0"	16"
	11'	13.5"	12.1"	11.2"	13.9"	4.0"	16"
	12'	12.9"	12.8"	11.6"	15.2"	4.0"	16"
	13'	12.2"	13.7"	12.2"	16.6"	4.0"	16"
	14'	11.5"	14.7"	12.9"	18.3"	4.0"	16"
	15'	10.8"	15.6"	13.4"	19.8"	4.0"	16"

F G 3.00" ¥ SHAFT (BY OTHERS) MUST FULLY ENGAGE BUSHING

NOTE 1:

MAXIMUM FAN DIAMETER EQUALS NOMINAL FAN DIAMETER. ADJUSTMENT OF ±1.5 INCHES\* POSSIBLE AT INSTALLATION \*BLADES WITH ATEX TIPS HAVE ADJUSTMENT OF -1.0" & +2.0" ON DIAMETER

		MAX	MAX	MAX			
MAX	BUSHING	#	*	о			
BLADES	TYPE	BORE	BORE	BORE	F	G	L
10	U	2.750"	2.938"	75	2.0"	2.7"	4000
10	w	3.750"	4.000"	100	2.2"	2.8"	7300